White Installation Tag

Installation Tag (White)

Installation Tag – Upon installation of any new fire protection system, the system shall have a tag permanently affixed to the panel for fire detection and alarm and fixed fire extinguishing systems. On kitchen fixed fire extinguishing systems, the tag shall be permanently affixed to the side of the fire suppression system control box. The installation tag shall be a minimum of $2\frac{3}{4}$ inches by $2\frac{3}{4}$ inches. Maximum size cannot exceed 5 inches by 5 inches. The tag shall be white in color and have a self adhesive backing.

DO NOT REMOVE BY ORDER OF THE STATE FIRE MARSHAL

INSTALLATION TAG

FIRM NAME	
CERTIFICATE OF REGISTRATION NUMBER	
TECH NAME	
TECH'S LICENSE NUMBER	
TECH'S SIGNATURE	
NFPA CODE & YEAR	
PLAN REVIEW NUMBER	
SERIAL/MODEL NUMBER	
INSTALLATION DATE//	